

Certificate of Compliance

Awarded to:

Peridot



TSS certifies that:

Production CER , located at Peridot 1072 Serpentine Lane, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-7) for particles $\geq 0.5 \mu\text{m}$ and $\geq 5.0 \mu\text{m}$ under At Rest/Static conditions.

Average rH: 43%

Refer to TSS Project Report NC-PDO222201A-1 for supporting data.

Presented by:



620 Hearst Avenue, Berkeley, CA 94710
(800) 877-7742 - www.techsafety.com

Effective Date: 04/08/2022

Expiration Date: 04/08/2023

Approved By: Audrey Barnett
Technical Writer
Technical Safety Services (TSS)

Certificate of Compliance

Awarded to:

Peridot



TSS certifies that:

Gown , located at Peridot 1072 Serpentine Lane, meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles $\geq 0.5 \mu\text{m}$ and $\geq 5.0 \mu\text{m}$ under At Rest/Static conditions.

Average rH: 43 %

Refer to TSS Project Report NC-PDO222201A-1 for supporting data.

Presented by:



620 Hearst Avenue, Berkeley, CA 94710
(800) 877-7742 - www.techsafety.com

Effective Date: 04/08/2022

Expiration Date: 04/08/2023

Approved By: Audrey Barnett
Technical Writer
Technical Safety Services (TSS)